



b-b


sc. 1:50

**a-a**

sc. 1:50


**Cos de ventilare Cv-2**

sc. 1:50

**Specificatia materialelor Cv-2**

Pozitia	Denumirea	buc.	Massa un. kg.	Nota
	<u>Cos de ventilare din metal Cv-2</u>	1		
1	L 100x6,5 GOST 8509-86 l= 370	2	3,72	7,44 kg
2	L 100x6,5 GOST 8509-86 l= 260	2	2,62	5,24 kg
3	L 50x5 GOST 8509-86 l= 370	2	1,40	2,80 kg
4	L 50x5 GOST 8509-86 l= 260	2	0,98	1,96 kg
5	L 50x5 GOST 8509-86 l= 1200	4	4,52	18,08 kg
6	—50x5 GOST 103-76 l= 300	4	0,47	1,88 kg
7	—50x5 GOST 103-76 l= 650	2	1,27	2,54 kg
8	Tabla zincata , δ=0,5mm	-	-	0,50 m ²
9	Plasa expandata zincata celula 10mmx20mm	-	-	0,40 m ²
10	Panouri SANDWICH antifoc de culoare albastra, δ=50mm	-	-	1,75 m ²
11	Sort din tabla zincata, δ=0,5mm, b=150mm, Σl= 6,5m	-	-	1,0 m ²
12	Sort din tabla zincata, δ=0,5mm, b=200mm, Σl= 1,7m	-	-	0,34 m ²
13	Ancora M6 l=65mm GOST 28778-90	4	0,032	0,128 kg

Nr inv. a orig	Data si semnatura Nr inv. schim.
----------------	----------------------------------

Schema cladirei

1. Plansa data se citeste cu pl.-16.

Mod.	Can.	Foaia	Nr.d.	Semnat.	Data	OBIECTIV NR. - 31.10-D/17-SAC		
ASP	Postolachi				03.18	Reparatie capitala a blocurilor E si D (sectia internare) ai cladirii medico-sanitare existente;		
ISP	Hihlat E.				03.18	din str. Decebal, 101, mun. Balti		
Elaborat	Ciobanu V.				03.18	Reparatie capitala		
						faza plansa planse		
						PE 27		
						Cos de ventilare Cv-2; Sectiunea a-a, b-b; Specificatia materialelor Cv-2.		
						SRL "GEO-CAD-PROIECT"		
						mun. Balti		