



Specificatia materialelor Cv-3

Pozitia	Denumirea	buc.	Massa un. kg.	Nota
	Cos de ventilare din metal Cv-3	1		
1	L 100x6,5 GOST 8509-86 l= 2380	2	23,94	47,88 kg
2	L 100x6,5 GOST 8509-86 l= 260	2	2,62	5,24 kg
3	L 50x5 GOST 8509-86 l= 2380	2	8,97	17,94 kg
4	L 50x5 GOST 8509-86 l= 260	2	0,98	1,96 kg
5	L 50x5 GOST 8509-86 l= 1200	4	4,52	18,08 kg
6	—50x5 GOST 103-76 l= 300	10	0,47	4,70 kg
7	—50x5 GOST 103-76 l= 650	5	1,27	6,35 kg
8	Tabla zincata , $\delta=0,5\text{mm}$	-	-	1,90 m ²
9	Plasa expandata zincata celula 10mmx20mm	-	-	1,20 m ²
10	Panouri SANDWICH antifoc de culoare albastra, $\delta=50\text{mm}$	-	-	6,60 m ²
11	Sort din tabla zincata, $\delta=0,5\text{mm}$, b=150mm, $\Sigma l= 10,5\text{m}$	-	-	1,58 m ²
12	Sort din tabla zincata, $\delta=0,5\text{mm}$, b=200mm, $\Sigma l= 5,7\text{m}$	-	-	1,14 m ²
13	Ancora M6 l=65mm GOST 28778-90	8	0,032	0,256 kg



1. Plansa data se citeste cu pl.-16.

						OBIECTIV NR. - 31.10-D/17-SAC			
						Reparatie capitala a blocurilor E si D (sectia internare) ai cladirii medico-sanitare existente; din str. Decebal, 101, mun. Balti			
Mod.	Can.	Foai	Nr.d.	Semnat.	Data				
						Reparatie capitala	faza	plansa	planse
ASP		Postolachi		03.18			PE	28	
ISP		Hihlat E.		03.18		Cos de ventilare Cv-3; Sectiunea a-a, b-b; Specificatia materialelor Cv-3.	SRL "GEO-CAD-PROIECT" mun. Balti		
Elaborat		Ciobanu V.		03.18					